

Supplemental Information to the
WCAC Packet

Agenda Item No 2

Equine Smarts DA 17-106

WCAC Meeting

February 6, 2018

RECEIVED

FEB 02 2018

DOUGLAS COUNTY
COMMUNITY DEVELOPMENT

Allerman Upper Virginia Irrigation Company Inc.
P O Box 55
Minden, Nevada 89423

January 30, 2018

Jeremy Hutchings
R O Anderson
P O Box 2229
Minden, Nevada 89423

Dear Jeremy,

The board of the Allerman Upper Virginia Irrigation Company met on January 30, 2018 and discussed the proposed culvert pipe to be installed at 1506 East Valley Road in Gardnerville Nevada (APN: 1320-35-001-030). After considerable discussion regarding the capacity of the Upper Allerman Canal and the sizes of culverts both upstream and downstream of your proposed culvert, the board moved to accept a culvert with a working capacity of 150 cubic feet per second with a flare inlet on the upstream side. The board further iterates that we accept no liability for any incidents that might arise or result from your culvert installation within our easement despite our acceptance of your culvert. If you have any questions feel free to contact me at (775) 790-0163 or e-mail frankgodecke@yahoo.com.

Sincerely,



Frank Godecke
Secretary-Treasurer

Cc: Douglas County Water Conveyance Advisory Committee